



Dutchess County BOCES - BETA

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S012852-01	123 Women BathRm Sink 1	Lead	3.87	ug/L		15	10/29/2016 10:39	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-02	123 Women BathRm Sink 2	Lead	2.89	ug/L		15	10/29/2016 10:43	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-03	B Wing Water Fountain	Lead	<0.50	ug/L		15	10/29/2016 10:47	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-04	125 Man BathRm Sink 1	Lead	18.8	ug/L		15	10/29/2016 10:50	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-05	125 Man BathRm Sink 2	Lead	169	ug/L		15	10/29/2016 10:54	11/16/2016 11:12	EPA 200.9	Drinking Water
S012852-06	125 Man BathRm Sink 3	Lead	<0.50	ug/L		15	10/29/2016 10:58	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-07	132 Kitchen Sink 1	Lead	2.15	ug/L		15	10/29/2016 11:02	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-08	134 Health Office Sink 1	Lead	<0.50	ug/L		15	10/29/2016 11:01	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-09	138A Girls Rm Sink 1	Lead	<0.50	ug/L		15	10/29/2016 11:12	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-10	138B Boys Rm Sink 1	Lead	1.29	ug/L		15	10/29/2016 11:20	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-11	137 Heart Rm Sink 1	Lead	<0.50	ug/L		15	10/29/2016 11:28	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-12	C Wing Break Rm Kitchen Sink	Lead	4.47	ug/L		15	10/29/2016 12:10	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-13	C Wing Water Fountain	Lead	<0.50	ug/L		15	10/29/2016 12:11	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-14	244 C Wing Sink	Lead	3.89	ug/L		15	10/29/2016 12:16	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-15	221A C Wing Sink BR	Lead	1.77	ug/L		15	10/29/2016 12:26	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-16	C Wing WBRs#1	Lead	11.1	ug/L		15	10/29/2016 12:33	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-17	C Wing WBRs#2	Lead	11.0	ug/L		15	10/29/2016 12:40	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-18	C Wing WBRs#3	Lead	30.8	ug/L		15	10/29/2016 12:40	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-19	C Wing WBRs#4	Lead	7.28	ug/L		15	10/29/2016 12:42	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-20	Water Fountain Hall D	Lead	2.83	ug/L		15	10/29/2016 10:54	11/7/2016 13:55	EPA 200.9	Drinking Water

Dutchess County BOCES

Daniel Trusz
5 BOCES Road
Poughkeepsie, NY 12601



SMITH
ENVIRONMENTAL
LABORATORY

4 Scenic Drive
Hyde Park, NY 12538
845-229-6536
NY ELAP ID: 10924

Dutchess County BOCES - BETA

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
						15				
S012852-21	Room 201 K.S. #2	Lead	1.88	ug/L		15	10/29/2016 10:59	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-22	Room 201 K.S. #4	Lead	21.1	ug/L		15	10/29/2016 11:02	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-23	GBRS #1 D Wing	Lead	2.94	ug/L		15	10/29/2016 11:09	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-24	GBRS #2 D Wing	Lead	<0.50	ug/L		15	10/29/2016 11:12	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-25	BBRS #1 D Wing	Lead	<0.50	ug/L		15	10/29/2016 11:17	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-26	BBRS #2 D Wing	Lead	<0.50	ug/L		15	10/29/2016 11:20	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-27	Rm #206 Kitchen Sink	Lead	<0.50	ug/L		15	10/29/2016 11:26	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-28	BBRS #1 D Wing	Lead	3.27	ug/L		15	10/29/2016 11:34	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-29	BBRS #3 D Wing	Lead	1.95	ug/L		15	10/29/2016 11:39	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-30	114 Kitchen S	Lead	<0.50	ug/L		15	10/29/2016 9:40	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-31	A Wing Fountain	Lead	4.64	ug/L		15	10/29/2016 9:46	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-32	A Wing Girls Rm BRS 1	Lead	1.24	ug/L		15	10/29/2016 9:46	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-33	A Wing Girls Rm BRS 2	Lead	1.35	ug/L		15	10/29/2016 9:50	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-34	A Wing Boys Rm BRS 1	Lead	1.83	ug/L		15	10/29/2016 9:54	11/7/2016 13:55	EPA 200.9	Drinking Water
S012852-35	A Wing Boys Rm BRS 2	Lead	<0.50	ug/L		15	10/29/2016 9:55	11/7/2016 13:55	EPA 200.9	Drinking Water

Key: < =Less Than; ug/L= micrograms per liter; MCL=Maximum Contaminant Level

Reviewed by _____
Dorothy DiNobile, Laboratory Director

Smith Laboratory is approved as an Environmental Testing Laboratory in conformance with the National Environmental Laboratory Accreditation Conference (NELAC) Standards. This test report pertains only to the above items analyzed on this sample as received by the laboratory. Information supplied by the client is assumed to be correct. This report must be reproduced in its entirety.