

Dutchess County BOCES - CTI Building

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S012659-01	CTI Mens Rm Sink 1 Wing A	Lead	18.4	ug/L		15	10/22/2016 11:25	11/8/2016 16:49	EPA 200.8	Drinking Water
S012659-02	CTI Mens Rm Sink 2 Wing A	Lead	11.7	ug/L		15	10/22/2016 11:25	11/8/2016 16:51	EPA 200.8	Drinking Water
S012659-03	CTI Rm 111 Closet Sink	Lead	28.0	ug/L		15	10/22/2016 11:30	11/8/2016 16:53	EPA 200.8	Drinking Water
S012659-04	CTI Rm 111 BRS	Lead	7.23	ug/L		15	10/22/2016 11:30	11/8/2016 16:56	EPA 200.8	Drinking Water
S012659-05	CTI Rm 110 BRS w/Shower	Lead	1.67	ug/L		15	10/22/2016 11:35	11/8/2016 16:58	EPA 200.8	Drinking Water
S012659-06	CTI Rm 110 BRS	Lead	30.1	ug/L		15	10/22/2016 11:35	11/8/2016 17:00	EPA 200.8	Drinking Water
S012659-07	CTI Rm 110 Kitchen Sink	Lead	32.3	ug/L		15	10/22/2016 11:40	11/8/2016 17:02	EPA 200.8	Drinking Water
S012659-08	CTI Rm 110 Kitchen Sink sprayer	Lead	9.83	ug/L		15	10/22/2016 11:45	11/8/2016 17:05	EPA 200.8	Drinking Water
S012659-09	CTI Rm 102 BRS	Lead	64.8	ug/L		15	10/22/2016 10:45	11/8/2016 17:07	EPA 200.8	Drinking Water
S012659-10	CTI Rm 105 BRS 1	Lead	17.0	ug/L		15	10/22/2016 10:50	11/8/2016 17:09	EPA 200.8	Drinking Water
S012659-11	CTI Rm 105 BRS 2	Lead	16.5	ug/L		15	10/22/2016 10:50	11/8/2016 17:21	EPA 200.8	Drinking Water
S012659-12	CTI Rm 106 BRS	Lead	16.2	ug/L		15	10/22/2016 10:55	11/8/2016 17:23	EPA 200.8	Drinking Water
S012659-13	CTI Rm 108 Sink	Lead	30.4	ug/L		15	10/22/2016 11:00	11/8/2016 17:25	EPA 200.8	Drinking Water
S012659-15	CTI girls BR sink 2 A wing	Lead	1.36	ug/L		15	10/22/2016 11:05	11/8/2016 17:27	EPA 200.8	Drinking Water
S012659-16	CTI Rm 109 sink	Lead	12.6	ug/L		15	10/22/2016 11:10	11/8/2016 17:30	EPA 200.8	Drinking Water
S012659-17	CTI Rm 109 BRS	Lead	19.7	ug/L		15	10/22/2016 11:10	11/8/2016 17:32	EPA 200.8	Drinking Water
S012659-18	CTI A wing fountain	Lead	<0.50	ug/L		15	10/22/2016 11:10	11/8/2016 17:34	EPA 200.8	Drinking Water

Dutchess County BOCES
Daniel Trusz
5 BOCES Road
Poughkeepsie, NY 12601



SMITH
ENVIRONMENTAL
LABORATORY

4 Scenic Drive
Hyde Park, NY 12538
845-229-6536
NY ELAP ID: 10924

Dutchess County BOCES - CTI Building

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S012659-19	CTI Mens BRS 1 Hall B	Lead	8.08	ug/L		15	10/22/2016 12:32	11/8/2016 17:37	EPA 200.8	Drinking Water
S012659-20	CTI Mens BRS 2 Hall B	Lead	9.92	ug/L		15	10/22/2016 12:35	11/8/2016 17:41	EPA 200.8	Drinking Water
S012659-21	CTI Ladies BRS 1 Hall B	Lead	10.6	ug/L		15	10/22/2016 12:40	11/8/2016 17:43	EPA 200.8	Drinking Water
S012659-23	CTI Water Fountain Hall B	Lead	<0.50	ug/L		15	10/22/2016 12:30	11/8/2016 17:55	EPA 200.8	Drinking Water
S012659-24	CTI 208 BRS	Lead	37.5	ug/L		15	10/22/2016 11:22	11/8/2016 17:57	EPA 200.8	Drinking Water
S012659-25	CTI 208 Sink	Lead	18.3	ug/L		15	10/22/2016 11:26	11/8/2016 17:59	EPA 200.8	Drinking Water
S012659-27	CTI 202 BRS	Lead	9.58	ug/L		15	10/22/2016 11:32	11/8/2016 18:02	EPA 200.8	Drinking Water
S012659-28	CTI 203A BRS	Lead	15.9	ug/L		15	10/22/2016 11:04	11/8/2016 18:04	EPA 200.8	Drinking Water
S012659-29	CTI 201 Sink	Lead	41.7	ug/L		15	10/22/2016 11:35	11/8/2016 18:06	EPA 200.8	Drinking Water
S012659-30	CTI 210 BRS	Lead	18.2	ug/L		15	10/22/2016 11:38	11/8/2016 18:08	EPA 200.8	Drinking Water
S012659-31	CTI 210 Sink	Lead	47.2	ug/L		15	10/22/2016 11:42	11/8/2016 18:11	EPA 200.8	Drinking Water
S012659-33	CTI Rm 03 BR Sink Lower A wing	Lead	8.14	ug/L		15	10/22/2016 12:20	11/8/2016 18:13	EPA 200.8	Drinking Water
S012659-34	CTI Rm 05 Lower A wing Sink 1	Lead	4.61	ug/L		15	10/22/2016 12:25	11/8/2016 18:15	EPA 200.8	Drinking Water
S012659-35	CTI Rm 06 Lower A wing Sink 2	Lead	9.84	ug/L		15	10/22/2016 12:25	11/9/2016 9:58	EPA 200.8	Drinking Water
S012659-36	CTI Rm 06 Lower A wing Sink 3	Lead	2.04	ug/L		15	10/22/2016 12:25	11/9/2016 10:00	EPA 200.8	Drinking Water
S012659-37	CTI Rm 08 Kit. Sink Lower A wing	Lead	6.79	ug/L		15	10/22/2016 12:35	11/9/2016 10:03	EPA 200.8	Drinking Water
S012659-38	CTI Main Office Sink	Lead	9.67	ug/L		15	10/22/2016 12:40	11/9/2016 10:05	EPA 200.8	Drinking Water

Dutchess County BOCES
Daniel Trusz
5 BOCES Road
Poughkeepsie, NY 12601



SMITH
ENVIRONMENTAL
LABORATORY

4 Scenic Drive
Hyde Park, NY 12538
845-229-6536
NY ELAP ID: 10924

Dutchess County BOCES - CTI Building

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S012659-39	CTI Main Office Mens Rm	Lead	29.3	ug/L		15	10/22/2016 12:40	11/9/2016 10:07	EPA 200.8	Drinking Water
S012659-40	CTI Main Office Girls Rm	Lead	13.6	ug/L		15	10/22/2016 12:40	11/9/2016 10:10	EPA 200.8	Drinking Water
S012659-41	CTI Main Office Rm Princ. office	Lead	50.0	ug/L		15	10/22/2016 12:45	11/9/2016 10:12	EPA 200.8	Drinking Water
S012659-42	CTI 102 Sinks 1	Lead	4.47	ug/L		15	10/22/2016 12:05	11/9/2016 10:14	EPA 200.8	Drinking Water
S012659-43	CTI 102 Sinks 2	Lead	13.3	ug/L		15	10/22/2016 12:06	11/9/2016 10:16	EPA 200.8	Drinking Water
S012659-44	CTI 01 Sinks 2	Lead	4.05	ug/L		15	10/22/2016 12:10	11/9/2016 10:19	EPA 200.8	Drinking Water
S012659-45	CTI 01 Sinks 1	Lead	4.31	ug/L		15	10/22/2016 12:20	11/9/2016 11:40	EPA 200.8	Drinking Water
S012659-46	CTI 01 Sinks 3	Lead	13.8	ug/L		15	10/22/2016 12:25	11/9/2016 11:43	EPA 200.8	Drinking Water
S012659-47	CTI Lower A Wing Mens Sink 1	Lead	3.20	ug/L		15	10/22/2016 12:26	11/9/2016 11:45	EPA 200.8	Drinking Water
S012659-48	CTI Lower A Wing Ladies Sink 1	Lead	29.8	ug/L		15	10/22/2016 12:35	11/9/2016 11:47	EPA 200.8	Drinking Water
S012659-49	CTI Lower A Wing Ladies Sink 2	Lead	12.8	ug/L		15	10/22/2016 12:45	11/9/2016 11:49	EPA 200.8	Drinking Water
S012659-50	CTI Lower A Wing LBRS #1	Lead	7.66	ug/L		15	10/22/2016 12:45	11/9/2016 11:52	EPA 200.8	Drinking Water
S012659-51	CTI Water Fountain	Lead	<0.50	ug/L		15	10/22/2016 11:00	11/9/2016 11:54	EPA 200.8	Drinking Water
S012659-52	CTI BRS C Wing Ladies 2	Lead	5.15	ug/L		15	10/22/2016 11:15	11/9/2016 11:56	EPA 200.8	Drinking Water
S012659-53	CTI BRS C Wing Ladies 1	Lead	6.94	ug/L		15	10/22/2016 11:20	11/9/2016 11:59	EPA 200.8	Drinking Water
S012659-54	CTI 313 Sink	Lead	57.9	ug/L		15	10/22/2016 11:30	11/9/2016 12:01	EPA 200.8	Drinking Water
S012659-55	CTI 311 Sink	Lead	15.50	ug/L		15	10/22/2016 11:35	11/9/2016 13:12	EPA 200.8	Drinking Water

Dutchess County BOCES
Daniel Trusz
5 BOCES Road
Poughkeepsie, NY 12601




SMITH
ENVIRONMENTAL
LABORATORY

4 Scenic Drive
Hyde Park, NY 12538
845-229-6536
NY ELAP ID: 10924

Dutchess County BOCES - CTI Building

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S012659-56	CTI 311 BRS	Lead	21.3	ug/L		15	10/22/2016 11:45	11/9/2016 13:15	EPA 200.8	Drinking Water
S012659-57	CTI 305 BRS	Lead	34.1	ug/L		15	10/22/2016 11:47	11/9/2016 13:17	EPA 200.8	Drinking Water
S012659-58	CTI 310 BRS	Lead	11.3	ug/L		15	10/22/2016 11:50	11/9/2016 13:19	EPA 200.8	Drinking Water
S012659-59	CTI 306 Sink	Lead	17.3	ug/L		15	10/22/2016 11:55	11/9/2016 13:21	EPA 200.8	Drinking Water
S012659-60	CTI 306 BRS	Lead	13.1	ug/L		15	10/22/2016 11:55	11/9/2016 13:24	EPA 200.8	Drinking Water
S012659-61	CTI 302 BRS	Lead	15.3	ug/L		15	10/22/2016 10:20	11/9/2016 13:26	EPA 200.8	Drinking Water
S012659-62	CTI 302 Fountain	Lead	64.5	ug/L		15	10/22/2016 10:22	11/9/2016 13:28	EPA 200.8	Drinking Water
S012659-63	CTI 303 Fountain	Lead	1.67	ug/L		15	10/22/2016 10:30	11/9/2016 13:31	EPA 200.8	Drinking Water
S012659-64	CTI 303 Sink	Lead	17.6	ug/L		15	10/22/2016 10:32	11/9/2016 13:33	EPA 200.8	Drinking Water
S012659-65	CTI 303 BRS	Lead	24.8	ug/L		15	10/22/2016 10:36	11/9/2016 13:44	EPA 200.8	Drinking Water
S012659-66	CTI 301 BRS	Lead	12.8	ug/L		15	10/22/2016 10:41	11/9/2016 13:47	EPA 200.8	Drinking Water
S012659-67	CTI 301 Coffee Rm Sink	Lead	12.8	ug/L		15	10/22/2016 10:50	11/9/2016 13:49	EPA 200.8	Drinking Water
S012659-68	CTI 304 BRS	Lead	26.1	ug/L		15	10/22/2016 10:52	11/9/2016 13:51	EPA 200.8	Drinking Water
S012659-69	CTI C Wing MBRS 1	Lead	5.69	ug/L		15	10/22/2016 10:57	11/9/2016 13:53	EPA 200.8	Drinking Water
S012659-70	CTI C Wing MBRS 2	Lead	4.51	ug/L		16	10/22/2016 11:02	11/9/2016 13:56	EPA 200.8	Drinking Water
S012659-71	CTI 214 BRS	Lead	19.8	ug/L		17	10/22/2016 12:00	11/9/2016 13:58	EPA 200.8	Drinking Water
S012659-72	CTI 214 Sink	Lead	66.7	ug/L		18	10/22/2016 12:00	11/9/2016 14:00	EPA 200.8	Drinking Water

Dutchess County BOCES
Daniel Trusz
5 BOCES Road
Poughkeepsie, NY 12601



SMITH
ENVIRONMENTAL
LABORATORY

4 Scenic Drive
Hyde Park, NY 12538
845-229-6536
NY ELAP ID: 10924

Dutchess County BOCES - CTI Building

Lab Sample ID	Sample Location	Analyte	Result	Units	Flag	Action Limit/ MCL	Sample Date	Analysis Date	Method	Matrix
S012659-73	CTI 211 Fountain	Lead	18.2	ug/L		19	10/22/2016 12:05	11/9/2016 14:05	EPA 200.8	Drinking Water
S012659-74	CTI 211 BR Sink	Lead	33.0	ug/L		20	10/22/2016 12:05	11/9/2016 14:07	EPA 200.8	Drinking Water
S012659-75	CTI 213B BR Sink	Lead	9.44	ug/L		21	10/22/2016 12:10	11/9/2016 16:25	EPA 200.8	Drinking Water
S012659-76	CTI 213B Kitchen Sink	Lead	6.09	ug/L		22	10/22/2016 12:10	11/9/2016 16:27	EPA 200.8	Drinking Water
S012659-77	CTI 212 BRS	Lead	39.8	ug/L		23	10/22/2016 12:10	11/9/2016 16:30	EPA 200.8	Drinking Water
S012659-78	CTI 205 Sink 1	Lead	18.6	ug/L		24	10/22/2016 10:39	11/9/2016 16:32	EPA 200.8	Drinking Water
S012659-79	CTI 205 Sink 2	Lead	2.04	ug/L		25	10/22/2016 10:40	11/9/2016 16:34	EPA 200.8	Drinking Water
S012659-80	CTI 205 Sink 3	Lead	2.10	ug/L		26	10/22/2016 10:41	11/9/2016 16:37	EPA 200.8	Drinking Water
S012659-81	CTI 205 Sink 4	Lead	1.89	ug/L		27	10/22/2016 10:41	11/9/2016 16:39	EPA 200.8	Drinking Water
S012659-82	CTI 205 Sink 5	Lead	2.12	ug/L		28	10/22/2016 10:42	11/9/2016 16:41	EPA 200.8	Drinking Water
S012659-83	CTI 205 BRS	Lead	20.0	ug/L		29	10/22/2016 10:43	11/9/2016 16:44	EPA 200.8	Drinking Water
S012659-84	CTI 207 BRS	Lead	17.7	ug/L		30	10/22/2016 10:51	11/9/2016 16:46	EPA 200.8	Drinking Water
S012659-85	CTI 207 A Sink	Lead	2.90	ug/L		31	10/22/2016 11:01	11/9/2016 16:57	EPA 200.8	Drinking Water
S012659-86	CTI 207 A BRS	Lead	2.51	ug/L		32	10/22/2016 11:03	11/9/2016 17:00	EPA 200.8	Drinking Water

Lead analysis performed by ELAP #12406

Reviewed by
Dorothy DiNobile, Laboratory Director

Key: <=Less Than; ug/L= micrograms per liter; MCL=Maximum Contaminant Level

Smith Laboratory is approved as an Environmental Testing Laboratory in conformance with the National Environmental Laboratory Accreditation Conference (NELAC) Standards. This test report pertains only to the above items analyzed on this sample as received by the laboratory. Information supplied by the client is assumed to be correct. This report must be reproduced in its entirety.

